

**AECOM**

Drawn: DP Date: 3/19/2026

Approved: DB Date: 3/19/2026

Project #: 60778704




**Legend**

- Drinking Water Well Sample PFAS Criteria Heat Map**
- No Detections of the Analyzed PFAS Substances
  - One or more of the Analyzed PFAS Substances Detected
  - One or more of the 7 PFAS Substances with Michigan DWC Detected at or Above Criteria
- Business with Compliance Monitoring**
- Elevated Levels of PFAS
  - Running Annual Average Exceedance

Note: Well sample locations that are not in a bounded area were part of the Cyclopure Comparison study.

- Surface Water Body
- Wexford AOI Sampling Areas
- Cadillac Industrial Park
- Cadillac Drinking Water Sampling Area
- US 131 & Mackinaw Trail AOI Sampling Area
- Wexford Tech Center AOI Sampling Area

Michigan Drinking Water Criteria (DWC), ppt  
 PFHxA = 400,000 PFBS = 420  
 PFOA = 8 PFHxS = 51  
 PFNA = 6 PFOS = 16  
 HFPO-DA = 370



**FIGURE 4**  
**PFAS CRITERIA HEAT MAP**

**WEXFORD AREAS OF INTEREST**  
**WEXFORD COUNTY, MI**