




LOW VOLTAGE CIRCUIT BKR SEC INJ TEST



CUSTOMER City of Richmond Dept. Public Utilities PAGE _____
ADDRESS _____ JOB # RVA22131-140
OWNER City of Richmond Dept. Public Utilities
REPRESENTATIVE _____ TELEPHONE _____
DATE 11/8/2022 AMBIENT TEMPERATURE 72 °F HUMIDITY 37 % EQPT. LOCATION DOUGLASDALE
SUBSTATION SWITCHGEAR POSITION MAIN



ASSESSMENT OF BREAKER: **PASSED ALL NETA MTS SPECIFICATIONS**

COMMENTS: _____
DEFICIENCIES: _____

TEST EQUIPMENT USED: MVT SECONDARY TEST SET TESTED BY: Rick Evans