

CITY OF MANCHESTER, NH DISCHARGE INFORMATION

WWTP Name	Permit No.	Permitted Flow (mgd)	Discharge Year	Annual Average Flow (mgd)	Volume of WW treated (MG)	Annual Average Influent BOD (mg/L)	Annual Average Influent TSS (mg/L)	Annual Average Effluent BOD (mg/L)	Annual Average Effluent TSS (mg/L)	Annual Average Percent Removal BOD (mg/L)	Annual Average Percent Removal TSS (mg/L)	Number of CSO Events	Volume of CSO Events (MG)	% of annual flow treated	\$ spent on CSO Control Plan since 2000
Manchester	NH0100447	34	2013	17.69	6,456.85	121	178	6.4	5.7	94.7	96.8	316	272	95.96	\$80 Million
			2014	18.74	6,840.10	132	157	6.1	6	95.4	96.2	296	377	94.78	
			2015	16.84	6,146.60	143	185	6.1	7	95.7	96.2	183	161	97.45	
			2016	17.35	6,332.75	145	194	5.4	6.4	96.3	96.7	134	131	97.97	
			2017	21.42	7,818.30	121	175	5.7	7.5	95.3	95.7	159	227	97.18	
			2018	25.96	9,475.40	95	157	5.7	8.8	94.0	94.4	177	364	96.30	
			2019	20.68	7,548.20	124	205	6.6	9.6	94.7	95.3	145	160	97.92	
			2020	19.30	7,044.50	135	208	7.0	8.1	94.8	96.1	144	154	97.86	
AVERAGE				19.75	7,207.84	127.00	182.38	6.13	7.39	95.11	95.93	194.25	230.75	96.93	